


2430 "E" Street, N. W.
Washington 25, D. C.
14 August 1953

25X1A9a



Dear Mr. [REDACTED]:

25X1A9a

25X1A

Returned herewith are one copy each of [REDACTED] Corporation's shop drawings Nos. L-2, L-3, 10, 11, and 12 and [REDACTED] drawings Nos. D2 through D5, E2, and E4, all of which may be approved by you as meeting requirements subject to same conditions as stated previously.


25X1A

With respect to the [REDACTED] drawings, it is noted that diameters of the anchor bolts are not shown.

25X1A

It is noted that none of the copies of drawings submitted by you to this Office bear indications of checking or approval by the General Contractor. If this is not being done, the attention of the Contractor should be called to Paragraph 1.9(d) of the General Conditions of the Specifications, which places upon him the responsibility for the original check and to point out any variations from the original design. This, in turn, should greatly facilitate your work and serve as an indication of the Contractor's competence.

Very truly yours,



25X1A9a

Enclosures
Drawings